



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7150-1076:0511
<b>CATEGORY:</b>	7150 - FIRE ALARM PULL BOXES
<b>LISTEE:</b>	KIDDE-FENWAL, INC 400 Main Street, Ashland, MA, 01721 Contact: Garland, Terrill (508) 881-2000 (508) 881-1773 Email: terrill.garland@carrier.com
<b>DESIGN:</b>	Model 76-330002-101 Noncoded Double Action Addressable Pull Box. Product is intended for use as signal initiating device in conjunction with listed fire alarm system control units. For indoor use with Model SGB-32S back box or outdoor use with Model SGB-32C back box.  Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as fire alarm pull boxes for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.  Compatible Fire Alarm Control Units:  Kidde-Fenwal, Inc. - Models ARIES® (CSFM Listing No. 7165-1076:0183), ARIES® NETLink (CSFM Listing No. 7165-1076:0195), ARIES®-SLX (CSFM Listing No. 7165-1076:0505), ARIES®-MLX (CSFM Listing No. 7165-1076:0506), FENWALNET 6000 (CSFM Listing No. 7165-1076:0184), and FenwalNET 8000-ML (CSFM Listing No. 7165-1076:0194).  Chemetron Fire Systems - Models MICRO SLX (CSFM Listing No. 7165-0061:0153) and MICRO MLX (CSFM Listing No. 7165-0061:0155).
<b>NOTES:</b>	

3-23-21 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/19/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division