



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7165-1076:0501
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
LISTEE:	KIDDE-FENWAL, INC 400 Main Street, Ashland, MA, 01721 Contact: Garland, Terrill (508) 881-2000 (508) 881-1773 Email: terrill.garland@carrier.com
DESIGN:	Model AEGIS-XLT fire alarm control unit. Local, releasing, auxiliary, automatic, manual, central station, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	120/240 VAC, Standby 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a fire alarm control unit for use with listee's separately listed electrically and functionally compatible initiating and indicating devices. Control unit meets the requirements of the 9th Edition of ANSI/UL 864. Refer to manufacturer's Installation Manual for details.
NOTES:	For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

07-26-16 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/12/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division