



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7165-1076:0505														
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)														
LISTEE:	KIDDE-FENWAL, INC 400 Main Street, Ashland, MA, 01721 Contact: Garland, Terrill (508) 881-2000 (508) 881-1773 Email: terrill.garland@carrier.com														
DESIGN:	<p>Model ARIES-SLX fire alarm control unit. Automatic, manual, local, central station, waterflow, sprinkler supervisory and releasing device services. Refer to the listee's data sheet for detailed product description and operational considerations. System components:</p> <table border="0"> <tr> <td>76-600000-901</td> <td>ARIES SLX Control Unit</td> </tr> <tr> <td>76-600000-904</td> <td>Motherboard</td> </tr> <tr> <td>76-600000-011</td> <td>Keypad/Display</td> </tr> <tr> <td>06-118394-002</td> <td>Power Supply</td> </tr> <tr> <td>06-220023-001</td> <td>In-Line Releasing Device (EOLD)</td> </tr> <tr> <td>76-600000-902</td> <td>Enclosure</td> </tr> <tr> <td>76-600000-009</td> <td>Network Interface Card</td> </tr> </table>	76-600000-901	ARIES SLX Control Unit	76-600000-904	Motherboard	76-600000-011	Keypad/Display	06-118394-002	Power Supply	06-220023-001	In-Line Releasing Device (EOLD)	76-600000-902	Enclosure	76-600000-009	Network Interface Card
76-600000-901	ARIES SLX Control Unit														
76-600000-904	Motherboard														
76-600000-011	Keypad/Display														
06-118394-002	Power Supply														
06-220023-001	In-Line Releasing Device (EOLD)														
76-600000-902	Enclosure														
76-600000-009	Network Interface Card														
RATING:	Primary: 120/240 VAC, Standby: 24 VDC														
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.														
MARKING:	Listee's name, model number, electrical rating, and UL label.														
APPROVAL:	<p>Listed as a fire alarm control unit for use with listee's separately listed electrically and functionally compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.</p> <p>This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2016 Edition.</p> <p>This control unit meets the requirements of UL-864, 9th Edition Standard.</p>														
NOTES:	For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.														



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

11-01-2018 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/19/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division