



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-1076:0508
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	KIDDE-FENWAL, INC 400 Main Street, Ashland, MA, 01721 Contact: Garland, Terrill (508) 881-2000 (508) 881-1773 Email: terrill.garland@carrier.com
DESIGN:	Model 76-600000-200 Maintenance Switch, normally closed switch which when switched from normal to maintenance will prevent the release of the suppression agent. Refer to listee's data sheet for additional detailed system description and operational considerations.
RATING:	Input Power: 24 VDC, 20 mA Dry Contacts: 125-250 VAC, 15 A; 30 VDC, 15 A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, intended installation environment (indoor and dry), and UL label.
APPROVAL:	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

03-24-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/19/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division